

# OSHA 1926.1408 Table A - Minimum Clearance Distances

<b>Voltage (nominal, kV, alternating current)</b>	<b>Minimum clearance distance (feet)</b>
<b>up to 50</b>	<b>10</b>
<b>over 50 to 200</b>	<b>15</b>
<b>over 200 to 350</b>	<b>20</b>
<b>over 350 to 500</b>	<b>25</b>
<b>over 500 to 750</b>	<b>35</b>
<b>over 750 to 1,000</b>	<b>45</b>
<b>over 1,000</b>	<b>(As established by the utility owner/ operator or registered, qualified professional engineer.)</b>

**Note: The value that follows “to” is up to and includes that value. For example, over 50 to 200 means up to and including 200kV.**